


PHASING METER WHERE INDICATED TRAFFIC LIGHT LABELS TO BE COMPLETED BY CONTRACTOR FOR AUTO C/O OPERATION REFER TO DWG 007139-C-0



SWITCHBOARD SPECIFICATION
 FACTORY BUILT FLOOR MOUNTED
 MODS 25
 REAR ACCESS FOR CABLING
 INCOMING CABLES TOP ENTRY
 OUTGOING CABLES TOP ENTRY
 BUSBARS 1250 AMPS
 FAULT LEVEL 50KA 1s
 SYSTEM: 415V 3PH 4W 50HZ
 PANEL TO BSEN 60439-1 FORM 4 TYPE 2
 BREAKING CAPACITY 25KA Icu
 PANEL TO IP 3X (BSEN60529-1)

PAINT FINISH LIGHT GREY RAL 7035
 LABELS (SCREW FIXED)
 EARTH BAR AND BONDING INCLUDES A MAIN EARTH BAR RUNNING THE FULL LENGTH OF THE SWITCHBOARD
 EARTH BAR (300mmSQ) 30mm x 10mm
 PANEL SUITABLE FOR EXTENSION
 CABLE GLANDS AND CABLE LUGS NOT INCLUDED

SLIGHT POSITIONAL CHANGES MAY OCCUR AS ASSEMBLY DICTATES
 ALL UNDIMENSIONED INTERNAL COPPERWORK IS DEPICITIVE ONLY
 FOR EASE OF HANDLING ON SITE, MULTI-SECTION PANELS CAN BE DESPATCHED AS SINGLE SECTIONS FOR ON-SITE ERECTION BY OTHERS

DIMENSIONS ARE mm
 No part of this document may be copied or reproduced by any means or transmitted in any form without the prior written permission of Switchgear Ltd

Design Approval		ACK No--		CUSTOMER--		ORDER No--	
Sign	Date	Designed by J Moss	Date-- 09.06.07	Approved by--	Date--	Quotation No-- 007139	NET/L:
PROJECT:- UOL - EC STONER ANNEX Main		Scale 1:20		Unit 3, The Sycamore Centre, Leigh St Attercliffe Common, Sheffield, S9 2FA Tel: 0114 244 5511 Fax: 0114 244 5599		DRG: A3007139-05	
Subject to Highlighted Special Design Yes / No		Scale		Unit 3, The Sycamore Centre, Leigh St Attercliffe Common, Sheffield, S9 2FA Tel: 0114 244 5511 Fax: 0114 244 5599		ISSUE A	