



SWITCHBOARD SPECIFICATION
FACTORY BUILT FLOOR MOUNTED
MODIS 25

FRONT ACCESS FOR CABLING
 INCOMING CABLES TOP ENTRY
 OUTGOING CABLES TOP ENTRY

FAULT LEVEL 50kA 1s
 SYSTEM: 4.15V 3PH ■ 50Hz
 PANEL TO BSEN 60439-1 FORM 4 TYPE 6
 BREAKING CAPACITY 50kA Icu
 PANEL TO IP 3X (BSEN60529-1)

PAINT FINISH LIGHT GREY RAL 7035
 LABELS (SCREW FIXED)

EARTH BAR AND BONDING INCLUDES A
 MAIN EARTH BAR RUNNING THE FULL
 LENGTH OF THE SWITCHBOARD
 EARTH BAR (300mmSQ) 30mm x 10mm
 PANEL SUITABLE FOR EXTENSION
 CABLE GLANDS AND CABLE LUGS
 NOT INCLUDED

SLIGHT POSITIONAL CHANGES MAY
 OCCUR AS ASSEMBLY DICTATES
 ALL UNDIMENSIONED INTERNAL
 COPPERWORK IS DEPICTIVE ONLY
 FOR EASE OF HANDLING ON SITE,
 MULTI-SECTION PANELS CAN BE
 DESPATCHED AS SINGLE SECTIONS FOR
 ON-SITE ERECTION ■■■■■

DIMENSIONS ARE mm
 No part of this document may be copied or reproduced
 by any means or transmitted in any form without the
 prior written permission of Switchgear Ltd

Design Approval		ACK No--	CUSTOMER--		ORDER No--	NET/1:	ISSUE
Sign	Date	Designed by J Moss	Date-- 21.10.08	Approved by--	Quotation No-- Q08498		
Subject to Highlighted Special Design Yes / No		PROJECT-- hallamshire chillers CHILLER 630A ISOLATOR PANEL		Switchgear Ltd Unit 28, Junction 34, Ind Est Greasebrough Road, Sheffield S19 7TN Tel: 0114 244 5511 Fax: 0114 244 5599		DRG: A3 Q08498-02	
Scale 1:20	Special Design Yes / No						